Area: 9 Combination SI: JALEXAND-U Count: 2

BUILDING INSPECTION NOTICE

B-Complete; E-Complete; M-Complete; P-Complete

Permit #: 18-122163-RS LI:

Supervisor Tel: 408 535-6873

Preferred: AM

Confirmation #: 01386369 Received: 07/17/2018 By: Phone Scheduled: 07/23/18

Tract: 4141 Lot: 83 # of Units: 0 Map: 852 G 3

Address: **5872 CASTANO DR SAN JOSE**

Contact: **Asaf** Phone: **(714) 366-2943** ETA Call: Y

Owner: LU CHIEN HUA AND WANG YUN WEN TRUSTEE (408)693-5064

Contractor: LEMON REMODELING Primary: (408)883-0191

Folder Name: (BEPM100%) KIT/BATH UPGRADE Subtype: Single Family Work Proposed: Additions/Alterations

Comments: AM request but not guaranteed

Related Permits:

Next Inspections Suggested

Insp Time: 50 Inspection time listed at the left includes 10 minutes travel time.

Number of Units: 01 Time inspection completed

Code			Description	OK	PA	CN	NR	NN	RF	Code			Description	OK	PA	CN	NR	NN	RF
4	1	3	**Electrical Rough**			X													
4	2	1	**Top-out**			X													
4	3	3	Rough Ducts		X														

Inspection Code: OK = Approved, PA = Partial Approval, CN = Correction Notice, NR = Not Ready, NN = Not Necessary, RF = Re-Inspection Fee Due

433-Kitchen, Bath Ducts OK

Remarks: 413-① Remove Old wires or Cut + Terminate wires. Set Red all wire nuts + junctions not in boxes in walls ② Protect Wires in Attic where they run accross Trusses. ③ 421-③ Insulate Hot, All to Kitchen, All 3/4 + Larger, first 5' of hot + Cold. ④ Fire Rated Laundry Box in Garage needed or 5 side Drywall Box
Add Complete Rewire to permit + Remove Service change if not going to change out. FAU + AC is a separate permit per Contractor

You have a total of 1 hour(s) remaining on this project as of Friday, July 20, 2018 10:36:52 AM.

Inspector's Signature: Print: MTurner Date: 07/23/18 Page: ___ of ___

City of San Jose Inspection Request Voice: (408) 535-3555 Please Retain For Your Records Field Copy