Area: 11 Combination

SI: JALEXAND Count: 1

BUILDING INSPECTION NOTICE

B-Complete; E-Complete; M-Complete; P-Complete

Permit #: 19-124996-RS

LI: Joseph Clarke

Supervisor Tel: 408 535-6873

Preferred:

Confirmation #: 01859219 Received: 10/05/2019 By: Internet Scheduled: 11/06/19

Tract: 571 Lot: 10 # of Units:0 Map: 833 E 6

Address: **2351 NEWHALL ST SAN JOSE**

Contact: **Asaf Bar Zvi** Phone: **7143662943** ETA Call: Y

Owner: NAISH ROBERT R AND SUSANN M Home: (408)243-3813

Contractor: LEMON REMODELING Work: (408)883-0191

Folder Name: (BEPM 100%)ALTERATION Subtype: Single Family Work Proposed: Additions/Alterations

Comments:

Related Permits:

Next Inspections Suggested

Insp Time: : 45 Inspection time listed at the left includes 10 minutes travel time.

Number of Units: 1

: Time inspection completed

Code			Description	OK	PA	CN	NR	NN	RF	Code			Description	OK	PA	CN	NR	NN	RF
3	4	2	Interior Shear/Bracing 10/2/19	X															
5	4	5	Insulation				X						Island receptacle						
9	4	8	**Building Final**			X							locations ok this						
9	3	8	Mech. final			X							time of Job only.						
9	2	8	Plumbing Final			X													
9	1	8	Elec. Final			X													
9	2	5	Gas pressure test				X												

Inspection Code: OK = Approved, PA = Partial Approval , CN = Correction Notice, NR = Not Ready, NN = Not Necessary, RF = Re-Inspection Fee Due

Remarks: 545-Ceiling insulation NR (see 10/2/19) 900's - hole in kitchen ceiling to be repaired, stove req. anti tip device, water hammer at DW to be verified, drywell to be 3' from foundation ETC... please see city website for drywell requirements (1.5" pipe, air gap, etc...), wires within 6' of attic access to be protected from damage (rat ways), metal cover on plastic box to be bonded, romex to FAU to be secured & protected, roll out protection still required, 30x30 service platform req. at FAU, 24x30 access way req to FAU, wires in panel to be terminated, gas pressure test required, HERS test required

You have a total of -0.34 hour(s) remaining on this project as of Tuesday, November 5, 2019 1:49:51 PM.

Inspector's Signature: Print: JAlexand Date: 11/06/19 Page: ___ of ___

City of San Jose Inspection Request Voice: (408) 535-3555 Please Retain For Your Records

Field Copy